

ADDENDUM

EOI NAME: PROTECTIVE SERVICES BUILDING SPACE ALLOCATION EOI #: 7290	ADDENDUM DESCRIPTION: MAINTENANCE BAY DIMENSIONS
	ADDENDUM #: 01
	DATE OF ISSUE: November 20, 2023
	ISSUED BY: Stephen Hanus
	PAGE(S): 01

INSTRUCTIONS:

1. Amend your copy of the Expression of Interest (EOI) in accordance with the detail below.
2. Retain one (1) copy for your file; sign a 2nd copy and attach to your submission as confirmation that the Addendum was taken into account in your EOI submission.
3. Failure to sign and attach this form with your submission may result in a non-compliant EOI.

DETAILS OF ADDENDUM:

1. **The EOI mentions the square footage of the bays. Can you provide the dimensions of the bays?**

Each bay measures 11m x 4.5m (36ft x 4.76ft) more or less.

Please note that corridor space of 1m (3.2 ft) on either end of each bay needs to be maintained for safe egress through the maintenance bays.

Name of Firm _____
Authorized Signature _____
Printed Name _____ **Date** _____